



ಶರಣಬಸವ
Sharnbasva



ವಿಶ್ವವಿದ್ಯಾಲಯ
University



Kalaburagi - 585103, Karnataka - India

ಕಲಬುರಗಿ - 585 103 ಕರ್ನಾಟಕ - ಭಾರತ ಸ್ಥಾಪನೆ 2017

Under the aegis of the Centenary Celebrated Sharnbasveshwar Vidya Vardhak Sangha's

Phone / Fax No. 08472-277852, 277853, 277854, 277855 www.sharnbasvauniversity.edu.in - email : Sharnbasvauniversity@gmail.com

UGC Status: Letter No. F.8-29/2017(CPP-I/PU), Dated 20 Dec. 2017. Enlisted by the University Grants Commission, New Delhi, in the list of Private Universities in India.
A Private University enacted by Govt. of Karnataka as "Sharnbasva University Act. 2012" Karnataka Act No. 17 of 2013. Notification No. ED 144 URC 2016 dated 29/07/2017

Ref. No. SUK/CIV/2022/ 2398

Date:09/04/2022

To,
The principal
Kenbridge School
KLB

Sample: Ro filtered water
Collected: SUPPLIED BY COSTUMER on 08/04/2022
Received at lab: 09/04/2022
Standard reference: IS 10500-2012drinking water standards
Project details Kenbridge School CBSE Affiliation no 830594
school code :-45527

WATER TEST REPORT

SL NO	TEST	UNIT	R-O water Result	STANDARD VALUE
1.	Chloride as (Cl)	mg/l	14.99	250-1000
2.	Total Alkalinity as(CaCO ₃)	mg/l	16	200-600
3.	Total Hardness as(CaCO ₃)	mg/l	8	200-600
4.	Calcium Hardness as (CaCO ₃)	mg/l	4	75-200
5.	Acidity	mg/l	8	--
6.	pH	-	6.7	6.5-8.5
7.	Total Dissolved Solids	mg/l	100	500-2000

NOTE : The sample is not collected by consulting agency.
Test result is based on water supplied by the consumer
As per water analyzed it is said to be fit for drinking

Name & Sign
Head Consultancy Cell
Department of Civil Engineering
Sharnbasva University Kalaburagi 585103

Name & Sign
Verifying Officers
Department of Civil Engineering
Sharnbasva University Kalaburagi
585103

Name & Sign
Chairman
Faculty of Engineering and
Technology (Co-Ed)
Department of Civil Engineering
Sharnbasva University Kalaburagi
585103